



**ENERG** Y IJA  
енергия - ενεργεια IE IA

**WAMAK**

WW 150 SHR HD  
Modul



55 °C

35 °C



**A++**

**A++**



62 dB



- dB

■ 67  
■ **67**  
■ 67  
kW

■ 77  
■ **77**  
■ 77  
kW



2015

811/2013

**WW 150 SHR HD**  
Modul

**ErP Data**

|                     | 55 °C      | 35 °C      |
|---------------------|------------|------------|
| Energy class        | <b>A++</b> | <b>A++</b> |
| $\eta$ [%]          | 176        | 231        |
| $P_{rated}$ [kW]    | 67         | 77         |
| $Q_{HE}$ [kWh/y]    | 35795      | 27309      |
| SCOP [-]            | 4.41       | 5.77       |
| $T_{bivalent}$ [°C] | -7         | -10        |

|                     | 55 °C      | 35 °C      |
|---------------------|------------|------------|
| Energy class        | <b>A++</b> | <b>A++</b> |
| $\eta$ [%]          | 154        | 228        |
| $P_{rated}$ [kW]    | 67         | 77         |
| $Q_{HE}$ [kWh/y]    | 49029      | 33020      |
| SCOP [-]            | 3.85       | 5.71       |
| $T_{bivalent}$ [°C] | -7         | -10        |

|                     | 55 °C      | 35 °C      |
|---------------------|------------|------------|
| Energy class        | <b>A++</b> | <b>A++</b> |
| $\eta$ [%]          | 229        | 230        |
| $P_{rated}$ [kW]    | 67         | 77         |
| $Q_{HE}$ [kWh/y]    | 17706      | 17660      |
| SCOP [-]            | 5.73       | 5.75       |
| $T_{bivalent}$ [°C] | -          | -          |

CONTROLLER



|            |           |        |
|------------|-----------|--------|
| + QAA55/75 | class VII | 3.5% ↓ |
| - QAA55/75 | class III | 1.5% ↓ |