




**ENERG** Y IJA  
енергия - ενεργεια IE IA

**WAMAK**

AWK 47 EVI



55 °C

35 °C



**A++**

**A++**



- dB



**72** dB

■ 48  
■ **54**  
■ 67  
kW

■ 47  
■ **54**  
■ 67  
kW



2015

811/2013

**AWK 47 EVI**

**ErP Data**

|                     | 55 °C      | 35 °C      |
|---------------------|------------|------------|
| Energy class        | <b>A++</b> | <b>A++</b> |
| $\eta$ [%]          | 134        | 170        |
| $P_{rated}$ [kW]    | 54         | 54         |
| $Q_{HE}$ [kWh/y]    | 28757      | 22601      |
| SCOP [-]            | 3.34       | 4.24       |
| $T_{bivalent}$ [°C] | -7         | -6         |

|                     | <b>A+</b> | <b>A++</b> |
|---------------------|-----------|------------|
| Energy class        | <b>A+</b> | <b>A++</b> |
| $\eta$ [%]          | 110       | 150        |
| $P_{rated}$ [kW]    | 48        | 47         |
| $Q_{HE}$ [kWh/y]    | 41766     | 30590      |
| SCOP [-]            | 2.75      | 3.76       |
| $T_{bivalent}$ [°C] | -7        | -6         |

|                     | <b>A++</b> | <b>A++</b> |
|---------------------|------------|------------|
| Energy class        | <b>A++</b> | <b>A++</b> |
| $\eta$ [%]          | 203        | 203        |
| $P_{rated}$ [kW]    | 67         | 67         |
| $Q_{HE}$ [kWh/y]    | 12131      | 12110      |
| SCOP [-]            | 5.07       | 5.08       |
| $T_{bivalent}$ [°C] | -          | -          |

CONTROLLER



|            |           |        |
|------------|-----------|--------|
| + QAA55/75 | class VII | 3.5% ↓ |
| - QAA55/75 | class III | 1.5% ↓ |