

ENERG Y IJA
енергия - ενεργεια IE IA

WAMAK


BW 09 EVI


55 °C

A++

35 °C

A++






44 dB

■ 9
■ **9**
■ 9


kW

■ 9
■ **9**
■ 9

kW



- dB



2015

811/2013

BW 09 EVI

ErP Data

	55 °C	35 °C
Energy class	A++	A++
η [%]	146	181
P_{rated} [kW]	9	9
Q_{HE} [kWh/y]	4751	3802
SCOP [-]	3.64	4.52
$T_{bivalent}$ [°C]	-	-

	55 °C	35 °C
Energy class	A++	A++
η [%]	132	184
P_{rated} [kW]	9	9
Q_{HE} [kWh/y]	6410	4583
SCOP [-]	3.30	4.60
$T_{bivalent}$ [°C]	-	-

	55 °C	35 °C
Energy class	A++	A++
η [%]	176	176
P_{rated} [kW]	9	9
Q_{HE} [kWh/y]	2462	2459
SCOP [-]	4.40	4.41
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓