




BW 36 EVI		ErP Data	
		55 °C	35 °C
Energy class		A++	A++
η [%]		146	182
P_{rated} [kW]		37	36
Q_{HE} [kWh/y]		20480	16377
SCOP [-]		3.65	4.56
$T_{bivalent}$ [°C]		-	-10

Energy class		A++	A++
η [%]		130	182
P_{rated} [kW]		37	36
Q_{HE} [kWh/y]		27643	19739
SCOP [-]		3.25	4.54
$T_{bivalent}$ [°C]		-	-10

Energy class		A++	A++
η [%]		181	181
P_{rated} [kW]		37	36
Q_{HE} [kWh/y]		10605	10592
SCOP [-]		4.52	4.53
$T_{bivalent}$ [°C]		-	-

CONTROLLER

+ QAA55/75

class **VII**

3.5% ↓

- QAA55/75

class **III**

1.5% ↓