




TBW 22 EVI		ErP Data	
		55 °C	35 °C
Energy class		A++	A++
η [%]		152	189
P_{rated} [kW]		23	22
Q_{HE} [kWh/y]		11982	9579
SCOP [-]		3.79	4.72
$T_{bivalent}$ [°C]		-	-

Energy class	A++	A++
η [%]	135	189
P_{rated} [kW]	23	22
Q_{HE} [kWh/y]	16178	11551
SCOP [-]	3.38	4.73
$T_{bivalent}$ [°C]	-	-

Energy class	A++	A++
η [%]	187	187
P_{rated} [kW]	23	22
Q_{HE} [kWh/y]	6202	6195
SCOP [-]	4.67	4.68
$T_{bivalent}$ [°C]	-	-

CONTROLLER

+ QAA55/75

class VII

3.5% ↓

- QAA55/75

class III

1.5% ↓