



ENERG Y IJA
енергия - ενεργεια IE IA

WAMAK

TBW 64 EVI



55 °C

35 °C



A++

A++



55 dB



- dB

66
66
66
kW

64
64
64
kW



2015

811/2013

TBW 64 EVI

ErP Data

	55 °C	35 °C
Energy class	A++	A++
η [%]	150	187
P_{rated} [kW]	66	64
Q_{HE} [kWh/y]	35256	28215
SCOP [-]	3.75	4.67
$T_{bivalent}$ [°C]	-	-10

	55 °C	35 °C
Energy class	A++	A++
η [%]	132	186
P_{rated} [kW]	66	64
Q_{HE} [kWh/y]	47572	34013
SCOP [-]	3.32	4.65
$T_{bivalent}$ [°C]	-	-10

	55 °C	35 °C
Energy class	A++	A++
η [%]	186	186
P_{rated} [kW]	66	64
Q_{HE} [kWh/y]	18268	18246
SCOP [-]	4.65	4.66
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓