




TBW 73 EVI		ErP Data	
		55 °C	35 °C
Energy class		A++	A++
η [%]		150	187
P_{rated} [kW]		75	73
Q_{HE} [kWh/y]		40143	32127
SCOP [-]		3.75	4.68
$T_{bivalent}$ [°C]		-	-10

Energy class	A++	A++
η [%]	133	186
P_{rated} [kW]	75	73
Q_{HE} [kWh/y]	54168	38729
SCOP [-]	3.32	4.65
$T_{bivalent}$ [°C]	-	-10

Energy class	A++	A++
η [%]	186	186
P_{rated} [kW]	75	73
Q_{HE} [kWh/y]	20800	20776
SCOP [-]	4.66	4.66
$T_{bivalent}$ [°C]	-	-

CONTROLER

+ QAA55/75

class VII

3.5% ↓

- QAA55/75

class III

1.5% ↓