




TBW 98 EVI		ErP Data	
		55 °C	35 °C
Energy class		A++	A++
η [%]		150	187
P_{rated} [kW]		101	98
Q_{HE} [kWh/y]		53927	43158
SCOP [-]		3.75	4.68
$T_{bivalent}$ [°C]		-10	-10

Energy class		A++	A++
η [%]		133	186
P_{rated} [kW]		101	98
Q_{HE} [kWh/y]		72767	52027
SCOP [-]		3.32	4.65
$T_{bivalent}$ [°C]		-10	-10

Energy class		A++	A++
η [%]		187	187
P_{rated} [kW]		101	98
Q_{HE} [kWh/y]		27942	27909
SCOP [-]		4.67	4.67
$T_{bivalent}$ [°C]		-	-

CONTROLER

+ QAA55/75

class VII

3.5% ↓

- QAA55/75

class III

1.5% ↓